BILL NO. S-88-12- 35

SPECIAL ORDINANCE NO. S- 10-89

AN ORDINANCE approving the awarding of Reference #8FLP022 by the City of Fort Wayne, Indiana, by and through its Department of Purchasing and Philadelphia Mixers for the Water Filtration Plant.

NOW, THEREFORE, BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY OF FORT WAYNE, INDIANA;

SECTION 1. That Reference #8FLP022 between the City of Fort Wayne, by and through its Department of Purchasing and Philadelphia Mixers for the Water Filtration Plant, is hereby ratified, and affirmed and approved in all respects, respectfully for:

> the purchase of two (2) carbon slurry mixers for the Water Filtration Plant;

involving a total cost of Forty Thousand and no/100 Dollars ($40,000.00).

SECTION 2. Prior Approval has been requested from Common Council on December 27, 1988. Two copies of said Reference are on file with the Office of the City Clerk and made available for public inspection, according to law.

SECTION 3. That this Ordinance shall be in full force and effect from and after its passage and any and all necessary approval by the Mayor.

Councilmember

APPROVED AS TO FORM
AND LEGALITY

J. Timothy McCaulay, City Attorney



PHILADELPHIA MIXERS

DIVISION OF PHILADELPHIA GEAR CORPORATION

PROPOSAL

for

CITY OF FORT WAYNE, INDIANA

GRISWALD STREET FILTRATION PLANT

CARBON SLURRY MIXERS

RECEIVED
1988 DEC 15 PM 1:33
PURCHASING

philadelphia mixers

November 23, 1988

City of Ft. Wayne
Griswald Street Filtration Plant
Ft. Wayne, IN 46802

Attention: Mr. John Brown

Reference: Proposal 839W-0055F

Gentlemen:

In response to your request for a recommended replacement for the two Philadelphia Mixers Model MV-16 now in service, we are pleased to offer the following equipment.

Two (2) Philadelphia Mixers Model 3809S-PTO complete with 30 HP 3 phase, 60 hertz, 230/460 volt TEFC high efficiency chemical duty 1800/1200 RPM motor providing a 56/84 RPM output to a 5" diameter x 214" long agitator shaft equipped with an upper flite 3 blade 55" diameter hydrofoil and a lower four blade curved blade turbine with stabillizer. All wetted parts to be 304 stainless steel.

PRICE . . . . . $20,000.00 net each

All pricing is fob, Palmyra, Pennsylvania and is subject to our Standard Terms and Conditions of Sale attached. The mixer model and agitator configuration may be subject to change and/or modification based on any changes in your process or operating conditions which may occur or which are not as we have interpreted them based on initial verbal data received.

The impeller and two speed motor configurations we are offering reflect configurations we have in carbon slurry service which have been eminently successful and which will offer a significant improvement over the agitator configuration presently in service.

After you have had an opportunity to review our proposal, I will be following up with you in the event there are questions regarding our proposal. Current delivery for these mixers is 16 weeks, subject to actual time of order placement.

Very truly yours,
PHILADELPHIA MIXERS

W. J. Sigward

WJS/t
cc: J. Hunter

THE W.J. SIGWARD COMPANY
6100 N. KEYSTONE AVENUE, SUITE 403, INDIANAPOLIS, IN 46220 ■ (317) 253-3920

Chemineer, Inc.
District Office
205 E. Carmel Drive
Carmel, Indiana 46032
(317) 846-2885

December 16, 1988

Ms. Patty Coffelt
CITY OF FT. WAYNE
City-County Building - Room 350
One Main Street
Ft. Wayne, Indiana 46802

Subject: Carbon Slurry Agitators
CHEMINEER
Quotation #073R-IND-88 Revision 1

Ms. Coffelt, per information from Mr. Neil Wisler and Mr. John Brown, we are pleased to offer Chemineer agitation equipment for the carbon slurry storage tanks at the Three Rivers Filtration Plant. Please consider a Model 6HTL-25 Turbine Agitator as specified in the enclosed proposal. Features will include:

Agitator operating speed 56/28 RPM

25 Hp, 1800/900 RPM two-speed motor, standard efficiency, chemical duty

4½" Dia., 216" extension shaft, 316 S.S., Turned down to 3" Dia. through bottom 12" of shaft length

46" Dia. straight blade (S-4) lower turbine, 316 S.S., at 216" extension

58" Dia. pitched-blade (P-4) upper turbine, 316 S.S., at 144" extension

Teflon lip seal for shaft seal, access/removal from above

In addition, please note the brief discussion on page 4 of Bulletin #711 which addresses the advantages of AGMA Quality 10 Hardened Helical and Spiral Bevel Gearing, Extra-Capacity Timken Tapered Roller Bearings, computer-controlled NC machining of components, and positive splash lubrication of the gearbox internals -- all of which are standard on Chemineer HT Series Drives.

THIS PROPOSAL IS SUBJECT TO THE TERMS AND CONDITIONS PRINTED ON THE FRONT AND BACK HEREOF.

The 6HTL-25 as noted herein is priced at $23,438.00. Package price for two (2) units is therefore $46,876.00. All pricing is F.O.B. Dayton, Ohio. Delivery is estimated at 14-16 weeks ARO. Terms and conditions are as listed on the reverse of this letterhead.

I would be more than happy to discuss any questions which you may have concerning this offering. If I can help in any way, please give me a call. As always, I am at your service.

CHEMINEER
Represented by
Campbell Industrial Sales

Joseph C. Almon
Engineering Representative

JCA:bl

enc.

cc: Mr. Neil Wisler - THREE RIVERS
Mr. John Brown - THREE RIVERS
Chemineer

P.S. - If we are favored with your order, please address it to:

CHEMINEER
c/o Campbell Industrial Sales
P. O. Box 629
Carmel, Indiana 46032

Read the first time in full and on motion by Burns, seconded by Talarico, and duly adopted, read the second time by title and referred to the Committee on City Utilities (and the City Plan Commission for recommendation) and Public Hearing to be held after due legal notice, at the Council ~~Conference~~ Room 128, City-County Building, Fort Wayne, Indiana, on _____, the _____, day of _____, 19____, at _____ o'clock ____.M.,E.S.T.

DATED: 12-27-88

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Read the third time in full and on motion by GiaQuinta, seconded by Bradbury, and duly adopted, placed on its passage. PASSED ~~LOST~~ by the following vote:

	AYES	NAYS	ABSTAINED	ABSENT
TOTAL VOTES	7			2
BRADBURY	✓			
BURNS	✓			
GiaQUINTA	✓			
HENRY	✓			
LONG	✓			
REDD	✓			
SCHMIDT				✓
STIER				✓
TALARICO	✓			

DATED: 1-10-89

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Passed and adopted by the Common Council of the City of Fort Wayne, Indiana, as (~~ANNEXATION~~) ~~(APPROPRIATION)~~ ~~(GENERAL)~~ (SPECIAL) (~~ZONING~~ MAP) ORDINANCE ~~RESOLUTION~~ NO. S-10-89 on the 10th day of January, 19 89,

ATTEST: Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

SEAL

Charles S. Redd
PRESIDING OFFICER

Presented by me to the Mayor of the City of Fort Wayne, Indiana, on the 11th day of January, 19 89, at the hour of 11:00 o'clock A.M.,E.S.T.

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Approved and signed by me this 15th day of January, 19 89, at the hour of 4:02 o'clock P.M.,E.S.T.

DIGEST SHEET

TITLE OF ORDINANCE: Special

DEPARTMENT REQUESTING ORDINANCE: Purchasing

S.88-12-35

SYNOPSIS OF ORDINANCE: An ordinance approving the award of Reference No. 9FLP022 with respect to the purchase of two (2) carbon slurry mixers for the Filtration Plant. The cost reflects the lowest and most responsible of two (2) vendors.

EFFECT OF PASSAGE: These are used to mix chemicals for the treatment of drinking water. Current mixers are 30 years old and in need of replacement.

EFFECT OF NON-PASSAGE: Could not treat drinking water properly.

MONIES INVOLVED: Philadelphia Mixers $40000.00

SOURCE OF FUNDING: Filtration Plant
Fund Line: 513-523-W101-4425

PRIOR APPROVAL 12/27/88

BILL NO. S-88-12-35

REPORT OF THE COMMITTEE ON CITY UTILITIES

WE, YOUR COMMITTEE ON CITY UTILITIES TO WHOM WAS REFERRED AN (ORDINANCE) ~~(RESOLUTION)~~ approving the awarding of Reference #8FLP022 by the City of Fort Wayne, Indiana, by and through its Department of Purchasing and Philadelphia Mixers for the Water Filtration Plant

HAVE HAD SAID (ORDINANCE) ~~(RESOLUTION)~~ UNDER CONSIDERATION AND BEG LEAVE TO REPORT BACK TO THE COMMON COUNCIL THAT SAID (ORDINANCE) ~~(RESOLUTION)~~

YES		NO
	MARK E. GiaQUINTA, CHAIRMAN	
	THOMAS C. HENRY, VICE CHAIRMAN	
	DAVID C. LONG	
	PAUL M. BURNS	
	SAMUEL J. TALARICO	

CONCURRED IN 1-3-89

Sandra E. Kennedy

Sandra E. Kennedy
City Clerk